



**ÉMI Építészeti Minőségellenőrző Innovációs
Nonprofit Kft.
Központi Laboratórium
Tűzvédelmi Szakági Laboratórium**

**ÉMI Non-Profit Limited Liability
Company for Quality and
Innovation in Building
Fire Testing Laboratory**

Central Laboratory: 1113 Budapest, Diószegi út 37.
Active Fire Testing Laboratory:
2000 Szentendre, Dózsa Györey út 26.

Phone: (36-1) 372-6113
Phone: (36-26) 310-526

No. TMT-19/2007-2010

CERTIFICATE

on the
FIRE SAFETY CONFORMITY
of a technical product

This Certificate is issued by ÉMI Nonprofit Kft. as an attestation body by appointment
No. 1-A/1014/2004
16 December 2004) of the Minister of Interior,

at the request of

**TELEFIRE FIRE & GAS DETECTORS LTD.
5 Halapid St. P.O.B. 7036 Petach-Tikva IL-49250, Israel**


This Certificate of Conformity is based on the test results outlined in the attached TEST REPORT.
Identification marking of technical product (brand name, type, marking):

ADR-812 TWO-CHANNEL INPUT MODULE

This CERTIFICATE OF CONFORMITY (FIRE SAFETY) is valid until 14. April 2016

Budapest, 8 of April 2011




Dr Matolcsy Károly
Scientific Director



ÉMI Nonprofit Kft.'s Central Laboratory,
Fire Testing Laboratory

- has been accredited under No. NAT-1-1110/2010 by the National Accreditation Body, in accordance with Hungarian Standard MSZ EN ISO/IEC 17025:2005; and
- it is a full rights member of EGOLF (European Group of Organisation for Fire Testing, Inspection and Certification).

KBiA-Xa-11-2009.09.17.

Product manufacturer: TELEFIRE Fire & Gas Detectors Ltd.
5 Halapid St. P.O.B. 7036 Petach-Tikva IL-49250, Israel

Distributor: TELEFIRE Fire & Gas Detectors Ltd.
5 Halapid St. P.O.B. 7036 Petach-Tikva IL-49250, Israel

Identification of testing facilities:

ÉMI Nonprofit Kft. Central Laboratory (H-1113 Budapest, Diószegi út 37)
Fire Testing Laboratory (H-2000 Szentendre, Dózsa György út 26)

Standards observed in testing the product:

- EN 54-18:2005 Fire detection and fire alarm systems. Part 18: Input/output devices,
- 9/2008.(II.22.) ÖTM –Decree for the Ministry of the Local Government and Regional Development

Brief description and technical data of the products:

The ADR-812 is a two-IDC monitor module that operates as an interface between the ADR-3000 addressable control panel and compatible two-wire conventional initiating devices or switches. The ADR-812 has a 24 VDC resettable power limited output. This output is interrupted on Reset, in order to reset devices that were latched on alarm. This 3 / 4 wire arrangement enables connection of detectors with higher power consumption.

Dimension:	133 × 119 × 36 mm
Operating Temperature Range:	0 ... +49°C
Operating Voltage:	20 V modulated (supplied by ADR-3000)
Relative Humidity:	10...93%
Current:	140 µA Max (Standby) /2,0 mA Max (Alarm)
Max output Current:	0,5 A (protected by a 0.5 A fuse)
External power supply:	24 VDC nominal
Input voltage:	16,0...26,0 VDC (when IDC is shorted)
EOL Resistor	5,1 kΩ
Weight:	113 g

Field of application of the product: *Fire detection/alarm components — Output/input module (96/577/EK):*


Identification of technical documents: M-800/2005-2010; TMT-19/2007


Technical conditions of applying the product safely:

The technical conditions are identified in section 2nd and 4th of the relevant No. M-800/2005-2010 Test Report.

No. **TMT-19/2007-2010** Certificate of Conformity (Fire Safety) covers a product which fully complies with the data and technical characteristics featuring in the Test Report marked M-800/2005-2010 and dated 18-02-2011, provided that the other conditions of application identified in section 2nd of the Test Report are met.

During the life of this Certificate of Conformity, ÉMI Nonprofit Kft. is entitled to inspect the product in the manufacturing and/or distribution process, with expenses paid by the customer.


Noémi Lőrík
Deputy Head of Active Fire
Testing Laboratory


László Kocsis
Head of Scientific Department
of Fire Protection